

CERTIFICATE OF COMPLIANCE

Certificate Number 20150901-E129899
Report Reference E129899-19940427
Issue Date 2015-SEPTEMBER-01

Issued to: CARLING TECHNOLOGIES
60 JOHNSON AVE
PLAINVILLE CT 06062

**This is to certify that
representative samples of**

CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-
BREAKER ENCLOSURES

USL, CNL - Molded case circuit breakers Type C rated 0.1 through 100 A; 80 V dc, 0.1 to 70 A; 120 V ac, .1 to 30 A; 240 V ac, 0.1-100 A, 125 V dc, 0.1-50 A; 120/240 V ac; 0.1-50 A, 125/250 V dc; 0.1-20 A, 277 Vac.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489 and CSA C22.2 No. 5-13 - Molded Case Circuit Breakers.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150901-E129899
Report Reference E129899-19940427
Issue Date 2015-SEPTEMBER-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Ratings: Standard –

<u>Cat. No.</u>	<u>No. of poles</u>	<u>Ampere Rating (A)</u>	<u>Voltage Rating (V)</u>
-	Single	.1-70	120 V ac
-	Single	.1-100	80 V dc
-	Single	.1-20	277 V ac
-	Single	.1-100	125 V dc
-	Single	.1-30	240 V ac
-	Two or three	.1-50	120/240 V ac (with 3 pole configuration 1 pole is neutral)
-	Two	.1-20	240 V ac
-	One or two	0.1-50	125/250 V dc

Interrupting Rating -

<u>Ampere Rating</u>	<u>Interrupting Rating</u>
0.1-50	10 kA, 120 V ac
0.1-50	5 kA, 125/250 V dc
51-70	5 kA, 120 V ac
0.1-100	50 kA, 80 V dc
0.1-100	10 kA, 80 V dc
0.1-30 A (with dual coil shunt trip)	10 kA, 120 V ac only
0.1-50	10kA, 120/240 V ac
0.1-20	10kA, 240 V ac
0.1-20	10kA, 277 V ac

Auxiliary Switch Ratings -

10.1 A, 125-250 V ac, 1/4 hp, 125 V ac.
0.1 A, 125 V ac.
0.1 A, 30 V dc.
0.1 A, 65 V dc.
1.0 A, 65 V dc.
0.1 A, 80 V dc
0.5 A, 80 V dc

Accessories -

The following optional accessories may be provided:


Auxiliary switch - See "RATINGS".

Remote operator - Type RB.

Shunt Trip (voltage pole) Ratings

6-125 Vdc

6-240 Vac



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

